



Certificate of Compliance

Certificate: 80043598

Master Contract: 601366

Project: 80043598

Date Issued: May 19, 2020

Issued To:

Balluff GmbH
Schurwaldstrasse 9
Neuhausen a.d.F., Baden-Württemberg 73765
Germany

The products listed below are eligible to bear the CSA Mark shown



Issued by: *Maria Gomes*
Maria Gomes

PRODUCTS

CLASS - C321123 - INDUSTRIAL CONTROL EQUIPMENT Motor Controllers-Auxiliary Devices

CLASS - C321163 - INDUSTRIAL CONTROL EQUIPMENT-Motor Controllers Auxiliary Devices-Certified to US Stds

Proximity switches types BES M*****-GNX***-B***-X06, BES M*****-GNX***-S04G-X04, BES M*****-GNX***-BT**-X05, BES M*****-GNX***-BT**-X03 Rated 8.3V max, and 3 mA.

Notes:

1. At the request of the submitter the switches were tested at -20 deg. C. and 60 deg. C.



Certificate: 80043598
Project: 80043598

Master Contract: 601366
Date Issued: May 19, 2020

APPLICABLE REQUIREMENTS

- | | |
|---|--|
| CAN/CSA C22.2 No. 60947-5-2-14 | - Low-voltage switchgear and controlgear - Part 5-2: Control circuit devices and switching elements - Proximity switches |
| <i>used in conjunction with</i>
CAN/CSA C22.2 No. 60947-1-13 | - Low-voltage switchgear and controlgear - Part 1: General rules |
| ANSI/UL 60947-5-2-2014 | - Low-voltage switchgear and controlgear - Part 5-2: Control circuit devices and switching elements - Proximity switches |
| <i>used in conjunction with</i>
ANSI/UL 60947-1-2013 | Low-voltage switchgear and controlgear - Part 1: General rules |

MARKINGS

Each unit shall bear all the required markings identified in the applicable certification report(s).
Note: The Listee's name and/or CSA file number shall replace the submitter's equivalent information (where applicable).